



Riverdale Water Tested Safe

The results are in from the latest test of our water supply. The chemical that spilled onto I-287 on May 7 and found its way into our storm drains and drainage ditches was **Methy Methacrylate**.

I am including the results from the previous test on February 14 so that you can compare them to the one taken on May 12. There was no increase in the concentration of that chemical as a result of the spill.

The Contaminant ID and Name are:
2295 - Methylmethacrylate.

Also, in speaking to the DEP I was told that we should have a report on the incident sometime within the next week to ten days. As soon as I receive it, it will be posted on the borough website:
www.RiverdaleNJ.gov

Thank you for being patient with us while we conducted the tests.

William Budesheim
Mayor
May 15, 2008

Riverdale Water Department
PO Box 6
Riverdale, NJ 07457

PWS ID# NJ1433001
Facility Name AA50111 - Dalton Drive
Facility ID# TP001005

Method

5242

Collection Date

2	14	2008
MM	DD	YY

Contaminant ID and Name	"X" if >MCL ug/l	MCL ug/l	MDI ug/l	Analysis Results	
				Sign (<)	ug/l
2978 - 1,1-Dichloroethane		50	0.10	<	0.10
2980 - 1,2-Dichloroethane		2	0.11	<	0.11
2977 - 1,1-Dichloroethene		2	0.19	<	0.19
2380 - cis-1,2-Dichloroethene		70	0.13	<	0.13
2979 - trans-1,2-Dichloroethene		100	0.14	<	0.14
2983 - 1,2-Dichloropropane		5	0.14	<	0.14
2412 - 1,3-Dichloropropane			0.15	<	0.15
2416 - 2,2-Dichloropropane			0.18	<	0.18
2410 - 1,1-Dichloropropene			0.22	<	0.22
2463 - 1,1-Dichloropropanone			1.40	<	1.40
2228 - cis-1,3-Dichloropropene			0.13	<	0.13
2224 - trans-1,3-Dichloropropene			0.11	<	0.11
2090 - Diethyl ether			0.24	<	0.24
2992 - Ethylbenzene		700	0.09	<	0.09
2293 - Ethyl methacrylate			0.14	<	0.14
2246 - Hexachlorobutadiene			0.40	<	0.40
2225 - Hexachloroethane			0.20	<	0.20
2269 - 2-Hexanone			0.24	<	0.24
2994 - Isopropylbenzene			0.24	<	0.24
2030 - 4-Isopropyltoluene			0.15	<	0.15
2467 - Methacrylonitrile			0.36	<	0.36
2297 - Methacrylate			0.18	<	0.18
2964 - Methylene chloride		3	0.22	<	0.22
2458 - Methyl iodide			0.10	<	0.10
2295 - Methylmethacrylate			0.18	<	0.18
2277 - 4-Methyl-2-pentanone			0.33	<	0.33
2251 - Methyl-t-butyl ether		70	0.10	<	0.10
2248 - Naphthalene		300	0.42	<	0.42
2254 - Nitrobenzene			26.58	<	26.58
2469 - 2-Nitropropane			0.85	<	0.85
2327 - Pentachloroethane			0.44	<	0.44
2468 - Propionitrile			2.80	<	2.80
2998 - n-Propylbenzene			0.16	<	0.16
2996 - Styrene		100	0.27	<	0.27
2986 - 1,1,1,2-Tetrachloroethane			0.14	<	0.14
2988 - 1,1,2,2-Tetrachloroethane		1	0.17	<	0.17
2987 - Tetrachloroethene		1	0.17	<	0.17
2263 - Tetrahydrofuran			2.63	<	2.63

03/12/08

PWS ID# NY143301
Facility Name AA53466
Facility ID# TPO01005

Method 524.2

Collection Date
5 12 2008
MM DD YY

Contaminant ID and Name	"X" if >MCL ug/l	MCL ug/l	MDL ug/l	Analysis Results	
				Sign (<)	ug/l
2978 - 1,1-Dichloroethane		50	0.10	<	0.10
2980 - 1,2-Dichloroethane		2	0.11	<	0.11
2977 - 1,1-Dichloroethene		2	0.19	<	0.19
2380 - cis-1,2-Dichloroethene		70	0.13	<	0.13
2979 - trans-1,2-Dichloroethene		100	0.14	<	0.14
2983 - 1,2-Dichloropropane		5	0.14	<	0.14
2412 - 1,3-Dichloropropane			0.15	<	0.15
2416 - 2,2-Dichloropropane			0.18	<	0.18
2410 - 1,1-Dichloropropene			0.22	<	0.22
2463 - 1,1-Dichloropropanone			1.40	<	1.40
2228 - cis-1,3-Dichloropropene			0.13	<	0.13
2224 - trans-1,3-Dichloropropene			0.11	<	0.11
2090 - Diethyl ether			0.24	<	0.24
2992 - Ethylbenzene		700	0.09	<	0.09
2293 - Ethyl methacrylate			0.14	<	0.14
2246 - Hexachlorobutadiene			0.40	<	0.40
2225 - Hexachloroethane			0.20	<	0.20
2269 - 2-Hexanone			0.24	<	0.24
2994 - Isopropylbenzene			0.24	<	0.24
2030 - 4-Isopropyltoluene			0.15	<	0.15
2467 - Methacrylonitrile			0.36	<	0.36
2297 - Methylacrylate			0.18	<	0.18
2964 - Methylene chloride		3	0.22	<	0.22
2458 - Methyl iodide			0.10	<	0.10
2295 - Methylmethacrylate			0.18	<	0.18
2277 - 4-Methyl-2-pentanone			0.33	<	0.33
2251 - Methyl-t-butyl ether		70	0.10	<	0.10
2248 - Naphthalene		300	0.42	<	0.42
2254 - Nitrobenzene			26.58	<	26.58
2469 - 2-Nitropropane			0.85	<	0.85
2327 - Pentachloroethane			0.44	<	0.44
2468 - Propionitrile			2.80	<	2.80
2998 - n-Propylbenzene			0.16	<	0.16
2996 - Styrene		100	0.27	<	0.27
2986 - 1,1,1,2-Tetrachloroethane			0.14	<	0.14
2988 - 1,1,2,2-Tetrachloroethane		1	0.17	<	0.17
2987 - Tetrachloroethene		1	0.17	<	0.17
2263 - Tetrahydrofuran			2.63	<	2.63